

Drake Park

DESCHUTES RIVER

Pump house

Restroom (4)

Designated public use

RIVERSIDE

KANSAS

Designated public use

IDAHO

 Electrical Access

At Pump House

- 24 - 120v 20 amp outlets
- 3 - 50 amp spider box outlets
Spider box required
- 1 - 30 amp 120/240v outlet twist lock
- 1 - 50 amp 120/240v

At Stage

- 12 - 120v 20 amp outlets
- 1 - 30 amp 120/240v twist lock outlet
- 1 - 50 amp spider box outlet
Spider box required
- 1 - 50 amp 120/240v outlet
- 8 - 120v 20amp outlets in cabinet



Stage - 2700 sf



Pavers




Vegetation



Turf - 4.6 acres



Two locations for 4 additional
ADA portable toilets each

 Drinking Fountain

 Water Access

 Trash Can

 Trees

N



0 30 60 120
Feet